

**SUPPLIER DECLARATION (Dich1 06\_24\_03\_EN)**

(according to UNI CEI EN ISO/IEC 17050-1:2010)

The manufacturer **GIACOMINI S.p.A.** located in Italy, San Maurizio d'Opaglio (NO) - Via per Alzo, no. 39, under its own responsibility **ATTESTS** that:

the disc check valves of the **R60** series, destined to be used in the following applications and according to the following use limits:

- *Fluids: water for thermal systems, sanitary water, water with glycol solutions (max. 30% glycol)*
- *Temperature range: 5°÷ 95°C (110°C for occasional peaks)*
- *Maximum working pressure:*

<i>Shutter made of metal</i>	<i>Shutter made of POM</i>
<i>Sizes from 3/8" to 1": 35 bar</i>	<i>Sizes from 3/8" to 1": 16 bar</i>
<i>Sizes from 1 ¼" to 2": 25 bar</i>	<i>Sizes from 1 ¼" to 2": 10 bar</i>
<i>Sizes from 2 ½" to 4": 12 bar</i>	<i>Sizes from 2 ½" to 4": 8 bar</i>

are properly designed and manufactured, using materials suitable to the distribution of water, according to the sound engineering practice in use, which ensures the safety of use in compliance with the technical requirements and the specific prescriptions, pertinent and applicable, referred to **art.4, par. 3, of PED 2014/68/UE Directive** with particular reference to **Tab.9 of Annex II – Conformity assessment tables**.

The disc check valves are also manufactured respecting design and production processes in compliance with the requirements of **UNI EN ISO 9001:2015** standard.

Moreover, GIACOMINI S.p.A. company **ATTESTS**

that the disc check valves here identified, in application of the above-mentioned technical requirements and prescriptions, are also **accompanied by sufficient use instructions and are not "CE marked"** since they have characteristics lower than the limits given at paragraph 1, letters a), b) e c) and at paragraph 2 of PED 2014/68/UE Directive.

Signed for and on behalf of Giacomini S.p.A.

The Technical Manager

Eng. Marco Rosa Brusin



San Maurizio d'Opaglio, 10/06/2024